

Annual Drinking Water Quality Report 2013  
**HARDY COUNTY PUBLIC SERVICE DISTRICT**  
Post Office Box 900  
Moorefield, West Virginia 26836  
PWS# WV3301613  
March 7, 2014

**Why am I receiving this report?**

In compliance with the Safe Drinking Water Act Amendments, the **Hardy County Public Service District** is providing its customers with this annual water quality report. This report explains where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The information in this report shows the results of our monitoring for the period of January 1st to December 31st, 2013 or earlier if not on a yearly schedule.

If you have any questions concerning this report, you may contact **Connie Sherman, Administrative Assistant, (304) 530-3048**. If you have any further questions, comments or suggestions, please attend any of our regularly scheduled water board meetings held on the **1<sup>st</sup> Wednesday** of every month at **10:00 a.m.** in the **conference room of our office located at 2094 US 220 South, Moorefield, WV**.

**Where does my water come from?**

Your drinking water is **surface** water from **Lost River Site 10** (Parker Hollow dam).

**Source Water Assessment**

A Source Water Assessment was conducted by the West Virginia Bureau for Public Health (WVBPH). The intake that supplies drinking water to the **Baker Water Treatment Plant** has a higher susceptibility to contamination, due to the sensitive nature of surface water supplies and the potential contaminant sources identified within the area. This does not mean that this intake will become contaminated; only that conditions are such that the surface water could be impacted by a potential contaminant source. Future contamination may be avoided by implementing protective measures. The source water assessment report which contains more information is available for review or a copy will be provided to you at our office during business hours or from the WVBPH 304-558-2981.

**Why must water be treated?**

All drinking water contains various amounts and kinds of contaminants. Federal and state regulations establish limits, controls, and treatment practices to minimize these contaminants and to reduce any subsequent health effects.

**Contaminants in Water**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits of contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate

that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The source of drinking water (both tap and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals, and, in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring, or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which can be naturally-occurring or the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Water Quality Data Table

Definitions of terms and abbreviations used in the table or report:

- **MCLG - Maximum Contaminant Level Goal**, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL - Maximum Contaminant Level**, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technique.

- **MRDLG - Maximum Residual Disinfectant Level Goal**, or the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect benefits of use of disinfectants to control microbial contaminants.
- **MRDL - Maximum Residual Disinfectant Level**, or the highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary to control microbial contaminants.
- **AL - Action Level**, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **TT - Treatment Technique**, or a required process intended to reduce the level of a contaminant in drinking water.

Abbreviations that may be found in the table:

- **ppm** - parts per million or milligrams per liter
- **ppb** - parts per billion or micrograms per liter
- **NTU** - Nephelometric Turbidity Unit, used to measure cloudiness in water
- **NE** - not established
- **N/A** - not applicable

The **Hardy County Public Service District** routinely monitor for contaminants in your drinking water according to federal and state laws. The tables below show the results of our monitoring for contaminants.

**Table of Test Results - Regulated Contaminants – Baker Water System**

Contaminant	Violation Y/N	Level	Unit of Measure	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
Turbidity	N	0.04 100% of monthly samples <0.3	NTU	0	TT	Soil runoff
Total organic carbon	N	3.0 Annual Average	ppm	NA	TT	Naturally present in the environment
Ecoli***	Y	1 positive sample		0	0	Human and animal fecal waste

<b>Inorganic Contaminants</b>						
Barium	N	0.0154	ppm	2	2	Discharge from drilling waste; erosion of natural deposits
Copper	N	0.112	ppm	1.3	AL=1.3	Corrosion of household plumbing
Lead*	N	5.9	ppb	0	AL=15	Corrosion of household plumbing
Nitrate	N	1.56	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits
Combined radium (226 & 228)	N	2.65	pCi/l	0	5	Erosion of natural deposits
Gross Alpha	N	.92	pCi/l	0	15	Erosion of natural deposits
<b>Volatile Organic Contaminants</b>						
Chlorine	N	1.1 Yearly Avg. Range 0.3 – 2.0	ppm	4 MRDLG	4 MRDL	Water additive used to control microbes
Haloacetic Acids** (HAAC5)	Y	103.8 Yearly Avg. Range 1.5 - 485	ppb	NA	60	By-product of drinking water disinfection
Total Trihalomethanes** (TTHMs)	Y	144.1 Yearly Avg. Range 67.7 - 443	ppb	NA	80	By-product of drinking water disinfection

\*Copper and lead samples were collected from 10 area residences on 04/18/13 and 11/22/13. Only the 90<sup>th</sup> percentile is reported.

The Hardy County Public Service District found elevated lead levels in one of our test sites. We have provided this residence with information concerning the control and abatement of lead in their household plumbing. Copper and lead occur in private homes due to household plumbing problems and is not a result of the quality of the water we produce.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

\*\*During the reporting year for 2013 we received a “Notice of Violation” letter from WVBPH for MCL violation for Haloacetic Acids and Trihalomethanes. We have taken every precaution and made every effort to return to compliance.

Some persons who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys or nervous system and may have an increased risk of getting cancer.

\*\*\*During the reporting year for 2013 we received a “Notice of Violation” letter from WVBPH for a positive ecoli sample. Further testing revealed non detects.

Fecal coliforms and ecoli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches or other symptoms. They may pose a special health risk for infants, young children, some of the elderly and people with severely compromised immune systems.

### Table of Test Results - Unregulated Contaminants

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
Sodium*	N	28.1	ppm	NE	20	Erosion of natural deposits
Sulfate	N	6.42	ppm	250	250	Erosion of natural deposits

\*Sodium is an unregulated contaminant. Our sodium level **exceeds** the guidance MCL. Anyone having a concern over sodium should contact their primary health care provider.

### Additional Information

All other water test results for the reporting year 2013 were all non-detects.

Turbidity is a measure of the cloudiness in drinking water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **The Hardy County PSD** is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.