

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Exceeded Maximum Contaminant Level (MCL) for Total Trihalomethanes
Hardy County Public Service District
Baker Water System – WV3301613

Our water system recently violated a drinking water requirement. Although this is not an emergency, you, as our customers have the right to know what happened, what you should do and what we are doing to correct the situation.

We routinely monitor for the presence of drinking water contaminants. Test results for 7/1/2020 and 9/30/2020 show that our system exceeds the standard or maximum contaminant level (MCL) for Total Trihalomethanes.

The average level of Total Trihalomethanes over the last four quarters was 92.43 ug/L at the Shawnee Road/WV SR 259 location. The standard for Total Trihalomethanes is 80.0 ug/L.

What should I do?

You do not need to use an alternative (e.g. bottles) water supply. However, if you have any specific health concerns, it is recommended that you consult with your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing Total Trihalomethanes (TTHM's) in excess of the MCL over many years may have an increased risk of getting cancer.

What happened? What is being done?

The Hardy County Public Service District is under construction of an ion exchange organics removal system at the water plant and has installed a mixing unit in the Parker Hollow water storage tank that we believe will allow us to realize the necessary TTHM levels needed to be in compliance.

For more information, please contact Logan Moyers, General Manager at (304) 530-3048 or the Hardy County Public Service District, Post Office Box 900, Moorefield, West Virginia 26836.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This is notice is being sent to you by the Hardy County Public Service District - Baker Water System

State Water System ID# WV3301613

Date Distributed: September 15, 2020